



12.47kV BUS #1 & BUS #2 PROTECTION

NAMEPLATE LEGEND				
NPLT NO.	LINE 1	LINE 2	LINE 3	SIZE
1	PANEL #5	12.47kV BUS #1 & #2 PROTECTION		1.25 X 6
2	12.47kV BUS TIE	BREAKER FAILURE PROTECTION	SEL-351S	0.75 X 3
3	CB 0024			0.75 X 3
4	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
5	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
6	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
7	12.47kV BUS #1	DIFFERENTIAL RELAY	SEL-587Z	0.75 X 3
8	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
9	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
10	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
11	12.47kV BUS #2	DIFFERENTIAL RELAY	SEL-587Z	0.75 X 3
12	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
13	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
14	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
15	86B1 LOCKOUT RELAY	BUS #1		0.75 X 3
16	86B2 LOCKOUT RELAY	BUS #2		0.75 X 3
17	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
18	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
19	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
20	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
21	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
22	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
23	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
24	SEE DRAWING 022074-NP04 FOR DETAILS			2 X 5
4L	P4R, 4FU1, 4FU2, 4FU3, 4FU4, 4FU5			0.5 X 1.5

NOTES:

1. NAMEPLATES ARE BLACK WITH WHITE LETTERS.
2. PROVIDE NAMEPLATES FOR FUSE BLOCKS, TERMINAL BLOCKS AND ANY OTHER INTERIOR DEVICE IDENTIFICATIONS.
3. LETTER HEIGHT FOR THIS NAMEPLATE IS 0.5".



Midwest Energy, Inc.
1330 Canterbury Rd.
Hays, Kansas 67601
(785) 625-3437

project	XXXXXX	contract
drawing	PANEL 7	rev. 0
sheet 1	of 1	sheets
file PANEL 7.dwg		