

XX 1. DENOTES BILL OF MATERIAL

2. DAMPENING CABLE TO BE 477 MCM ACSF.

3. ALL VERTICAL DIMENSIONS ARE FROM BOTTOM OF BASE PLATE.


4. END OF BUS TO EXTEND 2' EA. DIRECTION PAST BUS SUPPORT ON TERMINATION SUPPORT STRUCTURE.

E - EXPANSION FITTING
F - FIXED FITTING
S- SLIP FITTING
N.S. NEAR SIDE
F.S. FAR SIDE



MONTH DD, YYYY
KANSAS CITY, MO 64114
816-333-9400
LICENSEE NO. E-65

date MONTH DD, YYYY	detailed R. BECHER
designed R. BECHER	checked H. ABEER



Midwest Energy, Inc.
1330 Canterbury Rd.
Hays, Kansas 67601
(785) 625-3437

EAST HAYS SUBSTATION

SUBSTATION ELEVATION

SECTION A

project	193866	contract	WXX-XXXX-X
drawing	XXXE2001-1 —		rev. 0
sheet	1	of	X sheets
file XXXE2001-1.dwg			